



FIREFIGHTER II

6-1 GENERAL SKILL REQUIREMENTS

Evaluation Sheet: 6-1.2

Candidate: _____

Date: _____

Birth Date

Mo Day Yr _____

Last 4 digits of SS#: _____

STANDARD: 6-1.2 NFPA 1001, 2008 Edition		TASK: Determine the need for command; organize, coordinate, and function within an incident management system.			
PERFORMANCE OUTCOME: The candidate shall be able to determine the need for command, organize and coordinate an incident management system (IMS) until command is transferred, and be able to function within a commonly assigned IMS role.					
CONDITIONS: Given an incident scenario and a series of questions, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Determine the need for command				
2.	Implement an incident management system (IMS)				
3.	Organize an incident management structure				
4.	Coordinate an incident management system until transferred				
5.	Transfer command to an incoming incident commander				
6.	Assume an IMS role by describing the duties for the following:				
	a. Division, Group, or Sector Supervisor				
	b. Operations Section Chief				
	c. Incident Safety Officer				
	d. Public Information Officer				
	e. Liaison Officer				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____	_____	_____	_____
Evaluator (Print & Sign)	Date	Candidate	Date
_____	_____	_____	_____
Re-Test Evaluator	Date	Re-Test Candidate	Date



FIREFIGHTER II

6-2 FIRE DEPARTMENT COMMUNICATIONS

Evaluation Sheet: 6-2.1

6-2.1 COMPLETE INCIDENT REPORT

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-2.1 NFPA 1001, 2008 Edition		TASK: Complete a basic incident report.			
PERFORMANCE OUTCOME: The candidate shall be able to prepare a basic incident report that records all pertinent information, ensuring accuracy and completeness.					
CONDITIONS: Given a report form, guidelines, and incident information, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Determine the necessary data management codes used for recording coded information				
2.	Complete all applicable alarm information sections				
3.	Complete all applicable narrative sections				
4.	Operate the equipment normally used by local agencies for completing incident reports				
5.	Proofread report to ensure accuracy and completeness				
6.	Route, file, and/or forward report in accordance with local agency criteria				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



FIREFIGHTER II

6-2 FIRE DEPARTMENT COMMUNICATIONS
6-2.2 COMMUNICATE NEED FOR TEAM ASSISTANCE

Evaluation Sheet: 6-2.2

Candidate: _____ **Date:** _____
Birth Date _____
Mo Day Yr _____ **Last 4 digits of SS#:** _____

STANDARD: 6-2.2 NFPA 1001, 2008 Edition	TASK: Operate communications equipment to request team assistance.				
PERFORMANCE OUTCOME: While operating as a team leader, the candidate, following standard procedures, shall be able to provide situational reports and communicate the need for team assistance so that team assignments are performed safely.					
CONDITIONS: Given radio equipment, standard procedures, a team, and a scenario, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Identify and operate the basic features of selected radio equipment				
2.	Operate radio equipment in accordance with standard operating procedures				
3.	Transmit situation reports that accurately communicate conditions and the team's situational status				
4.	Identify conditions that warrant the need for additional personnel				
5.	Identify conditions that warrant the need for replacement personnel				
6.	Effectively communicate a request for team assistance within an incident management system				
RETEST APPROVED BY: _____		RETEST EVALUATOR: _____			

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

**6-3 FIREGROUND OPERATIONS
6-3.1 EXTINGUISH IGNITABLE LIQUID FIRE**

Evaluation Sheet: 6-3.1A

Candidate: _____ **Date:** _____
Birth Date _____
Mo Day Yr _____ **Last 4 digits of SS#:** _____

STANDARD: 6-3.1A NFPA 1001, 2008 Edition		TASK: Assemble a foam fire stream.			
PERFORMANCE OUTCOME: While operating as a team leader, the candidate shall be able to select the proper foam concentrate, assemble, and place into operation, a foam fire stream for a given ignitable liquid fuel and conditions.					
CONDITIONS: Given a scenario, an attack line, a foam proportioning device, a selection of foam concentrate, and a water supply, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Select the appropriate foam concentrate for the given fuel and conditions				
2.	Prepare the foam concentrate for the given fuel and conditions				
3.	Assemble the foam proportioning device with the foam concentrate				
4.	Adjust the foam proportioning device based on the selected foam concentrate				
5.	Assemble, position, and prepare the hose line for fire attack				
6.	Assemble, position, and prepare personnel for fire attack				
7.	Charge the hoseline so that it produces a properly proportioned foam fire stream				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____	_____	_____	_____
Evaluator (Print & Sign)	Date	Candidate	Date
_____	_____	_____	_____
Re-Test Evaluator	Date	Re-Test Candidate	Date



FIREFIGHTER II

6-3 FIREGROUND OPERATIONS
6-3.1 EXTINGUISH IGNITABLE LIQUID FIRE

Evaluation Sheet: 6-3.1B

Candidate: _____ **Date:** _____
Birth Date _____
Mo Day Yr _____ **Last 4 digits of SS#:** _____

STANDARD: 6-3.1B NFPA 1001, 2008 Edition		TASK: Extinguish an ignitable liquid fire using a foam fire stream.			
PERFORMANCE OUTCOME: While operating as a team leader, the candidate shall be able to extinguish an ignitable liquid fire by blanketing a foam fire stream over the fuel's surface, re-ignition is prevented, and team safety is maintained.					
CONDITIONS: Given a live fire or a simulated scenario, an assembled foam fire stream, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Prepare personnel, place attack line in position upwind, and check nozzle for proper production of foam solution				
2.	Coordinate the attack team's advancement toward the fire so that a smooth and safe approach is maintained. Choose one:				
	a. Apply a foam blanket over the fuel's surface by using the Roll-On Method				
	b. Apply a foam blanket over the fuel's surface by using the Bank-Down Method				
	c. Apply a foam blanket over the fuel's surface by using the Rain-Down Method				
3.	Prevent re-ignition by maintaining a foam blanket				
4.	Coordinate the attack team's retreat so that the hazard is faced until the entire team reaches a safe haven				
5.	Maintained the personal safety of all attack team members throughout scenario				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____	_____	_____	_____
Evaluator (Print & Sign)	Date	Candidate	Date
_____	_____	_____	_____
Re-Test Evaluator	Date	Re-Test Candidate	Date



FIREFIGHTER II

6-3 FIREGROUND OPERATIONS

Evaluation Sheet: 6-3.2A

6-3.2 COORDINATE INTERIOR ATTACK – GROUND LEVEL

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-3.2A NFPA 1001, 2008 Edition		TASK: Coordinate an interior fire attack team for a structure fire at ground level.			
PERFORMANCE OUTCOME: While operating as a team leader, the candidate shall be able to coordinate the interior attack of a structure fire at ground level by maintaining crew integrity, predicting fire behavior, forecasting developing hazards, and selecting the proper attack technique while incorporating forcible entry, ventilation, and search and rescue activities.					
CONDITIONS: Given a grade level fire scenario, attack lines, personnel, and tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Assemble all of the required personnel, attack lines, needed equipment, and forcible entry tools				
2.	Communicate the team's action plan for entry				
3.	Select, communicate, and coordinate the application of an (choose one):				
	a. In-direct attack for intense fire conditions				
	b. Combination attack for moderate fire conditions				
	c. Direct attack for tenable fire conditions				
4.	Conduct a size-up that considers the scenario's anticipated fire spread and development				
5.	Determine any developing and/or potential hazardous building or fire conditions				
6.	Incorporate forcible entry, ventilation, and search and rescue procedures into the team's initial fire attack efforts				
7.	Coordinate the attack team's efforts while maintaining the personal safety of all personnel				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments:

_____	_____	_____	_____
Evaluator (Print & Sign)	Date	Candidate	Date
_____	_____	_____	_____
Re-Test Evaluator	Date	Re-Test Candidate	Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-3 FIREGROUND OPERATIONS

Evaluation Sheet: 6-3.2B

6-3.2 COORDINATE INTERIOR ATTACK – ABOVE GROUND LEVEL

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-3.2B NFPA 1001, 2008 Edition		TASK: Coordinate an interior fire attack team for a structure fire above ground.			
PERFORMANCE OUTCOME: While operating as a team leader, the candidate shall be able to coordinate the interior attack of a structure fire above ground by maintaining crew integrity, predicting fire behavior, forecasting developing hazards, and selecting the proper attack technique while incorporating forcible entry, ventilation, and search and rescue activities.					
CONDITIONS: Given an above ground fire scenario, attack lines, personnel, and tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Assemble all of the required personnel, attack lines, needed equipment, and forcible entry tools				
2.	Advance the team to a safe haven assembly point located directly below the fire area				
3.	Communicate the team's action plan for advancement and entry				
4.	Select, communicate, and coordinate the application of an (choose one):				
	a. In-direct attack for intense fire conditions				
	b. Combination attack for moderate fire conditions				
	c. Direct attack for tenable fire conditions				
5.	Conduct a size-up that considers the scenario's anticipated fire spread and development				
6.	Determine any developing and/or potential hazardous building or fire conditions				
7.	Incorporate forcible entry, ventilation, and search and rescue procedures into the team's initial fire attack efforts				
8.	Coordinate the attack team's efforts while maintaining the personal safety of all personnel				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____	_____	_____	_____
Evaluator (Print & Sign)	Date	Candidate	Date
_____	_____	_____	_____
Re-Test Evaluator	Date	Re-Test Candidate	Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-3 FIREGROUND OPERATIONS

Evaluation Sheet: 6-3.2C

6-3.2 COORDINATE INTERIOR ATTACK – BELOW GRADE LEVEL

Candidate: _____ **Date:** _____
Birth Date _____
Mo Day Yr _____ **Last 4 digits of SS#:** _____

STANDARD: 6-3.2C NFPA 1001, 2008 Edition		TASK: Coordinate an interior fire attack team for a structure fire below grade or in a basement.			
PERFORMANCE OUTCOME: While operating as a team leader, the candidate shall be able to coordinate the interior attack of a structure fire in a basement by maintaining crew integrity, predicting fire behavior, forecasting developing hazards, and selecting the proper attack technique while incorporating forcible entry, ventilation, and search and rescue activities.					
CONDITIONS: Given a basement fire scenario, attack lines, personnel, and tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Assemble all of the required personnel, attack lines, needed equipment, and forcible entry tools				
2.	Ensure that adequate ventilation is established prior to entry				
3.	Communicate the team's action plan for advancement and entry				
4.	Select, communicate, and coordinate the application of an (choose one):				
	a. In-direct attack for intense fire conditions				
	b. Combination attack for moderate fire conditions				
	c. Direct attack for tenable fire conditions				
5.	Conduct a size-up that considers the scenario's anticipated fire spread and development				
6.	Determine any developing and/or potential hazardous building or fire conditions				
7.	Incorporate forcible entry, ventilation, and search and rescue procedures into the team's initial fire attack efforts				
8.	Coordinate the attack team's efforts while maintaining the personal safety of all personnel				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-3 FIREGROUND OPERATIONS

Evaluation Sheet: 6-3.2D

6-3.2 COORDINATE INTERIOR ATTACK – ATTIC

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-3.2D NFPA 1001, 2008 Edition		TASK: Coordinate an interior fire attack team for a structure fire in an attic.			
PERFORMANCE OUTCOME: While operating as a team leader, the candidate shall be able to coordinate the interior attack of a structure fire in an attic by maintaining crew integrity, predicting fire behavior, forecasting developing hazards, and selecting the proper attack technique while incorporating forcible entry, ventilation, and search and rescue activities.					
CONDITIONS: Given an attic fire scenario, attack lines, personnel, and tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Assemble all of the required personnel, attack lines, needed equipment, and forcible entry tools				
2.	Communicate the team's action plan for entry				
3.	Evaluate and forecast the given fire scenario's anticipated growth and development				
4.	Select an attic access point and coordinate efforts to provide access to area of involvement for fire attack				
5.	Select, communicate, and coordinate the application of an (choose one):				
	a. In-direct attack for intense fire conditions				
	b. Combination attack for moderate fire conditions				
	c. Direct attack for tenable fire conditions				
6.	Conduct a size-up that considers the scenario's anticipated fire spread and development				
7.	Incorporate forcible entry, ventilation, and search and rescue procedures into the team's initial fire attack efforts				
8.	Coordinate the attack team's efforts while maintaining the personal safety of all personnel				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-3 FIREGROUND OPERATIONS

Evaluation Sheet: 6-3.3

6-3.3 CONTROL FLAMMABLE GAS CYLINDER FIRE

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-3.3 NFPA 1001, 2008 Edition		TASK: Control a flammable gas cylinder fire.			
PERFORMANCE OUTCOME: While operating under the direct supervision of a team leader, the candidate shall be able to control a flammable gas cylinder fire by advancing a hose line to a point where control valves can be operated.					
CONDITIONS: Given a flammable gas cylinder fire scenario, an attack line, and tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Advance toward the fire so that a smooth, controlled, and safe approach is maintained				
2.	As directed, operate the nozzle and adjust patterns for the various techniques of using a:				
	a. Straight stream for reach and initial cooling				
	b. Narrow fog stream to cool the cylinder				
	c. Wide fog stream to shield personnel from flames and to push flames away from control valves				
3.	Cite the common indicators used for assessing cylinder integrity and monitoring for changing conditions				
4.	Select appropriate procedures for when changes in conditions occur				
5.	Advance and position fire streams in a manner that provides safe access for personnel to operate control valves				
6.	Apply the fire stream without extinguishing the flames unless leaking gas has been stopped				
7.	Operate control valves so that gas flow is stopped				
8.	While facing the hazard, retreat in a smooth and controlled manner until the entire team reaches a safe haven				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



FIREFIGHTER II

6-3 FIREGROUND OPERATIONS

Evaluation Sheet: 6-3.4

6-3.4 PROTECT EVIDENCE – FIRE CAUSE AND ORIGIN

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-3.4 NFPA 1001, 2008 Edition		TASK: Protect evidence of fire cause and origin.			
PERFORMANCE OUTCOME: The candidate shall be able to protect evidence of fire cause and origin so that the evidence is properly noted and protected from further disturbance until turned over to fire investigators.					
CONDITIONS: Given a fire cause and origin scenario, a flashlight, and overhaul tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Identify the indicators commonly used to locate a fire's point of origin				
2.	Recognize the indicators commonly used to identify possible sources of fire cause				
3.	Recognize possible signs of arson (such as trailers, accelerants, incendiary devices, etc.)				
4.	Protect evidence from being destroyed or improperly handled during salvage and overhaul operations				
5.	Preserve evidence by securing the immediate area				
6.	Secure the scene in accordance with local agency procedures				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-4 RESCUE OPERATIONS

Evaluation Sheet: 6-4.1A

6-4.1 EXTRICATE A VICTIM FROM MOTOR VEHICLE

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-4.1A NFPA 1001, 2008 Edition		TASK: Extricate a victim entrapped in a motor vehicle.			
PERFORMANCE OUTCOME: While operating as a member of a team, the candidate shall be able to extricate a victim entrapped in a vehicle so that the victim can be disentangled without causing further injury and manage hazards.					
CONDITIONS: Given a vehicle extrication scenario, stabilization, and extrication tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Size up the situation to identify hazards, determine required stabilization, and select extrication techniques				
2.	Stabilize the vehicle				
3.	Cover the victim, as required, to protect from injury.				
4.	Operate both hand and power extrication tools in a safe and efficient manner. Choose one of the following and apply appropriate techniques for moving or removing:				
	a. Vehicle roofs				
	b. Vehicle doors				
	c. Vehicle windshields and windows				
	d. Vehicle steering wheels and/or columns				
	e. Vehicle dashboards				
5.	Perform extrication techniques so that the victim can be disentangled without undue further injury				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____ Evaluator (Print & Sign)	_____ Date	_____ Candidate	_____ Date
_____ Re-Test Evaluator	_____ Date	_____ Re-Test Candidate	_____ Date



FIREFIGHTER II

6-4 RESCUE OPERATIONS

Evaluation Sheet: 6-4.1B

6-4.1 EXTRICATE A VICTIM FROM MOTOR VEHICLE

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-4.1B NFPA 1001, 2008 Edition		TASK: Set up and operate Hydraulic Rescue Spreader.			
PERFORMANCE OUTCOME: The candidate, wearing full protective clothing and eye protection, shall demonstrate the proper set-up and use of Hydraulic Rescue Spreaders. An assistant may operate the hydraulic pump under the direction of the candidate.					
CONDITIONS: Given personal protective clothing (boots, pants, coat, hood, gloves, eye protection, and helmet), Hydraulic Rescue Spreader, hydraulic pump, connectors, and necessary hand tools, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Inspect all furnished hydraulic equipment for damage				
2.	Position hydraulic pump outside the work area within hose reach of the scene				
3.	Connect the spreader tool to the pump with secure connections				
4.	Gain a purchase point				
5.	Close the spreader arms				
6.	Insert the tips of the spreader, at the proper angle, into the object to be spread				
7.	Safely operate the spreader arms to spread the object				
8.	Close the spreader arms and remove the spreader tips from the work				
9.	Disconnect the spreader from the pump				
10.	Place the spreader and all components in the designated area in a ready state for reuse				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____	_____	_____	_____
Evaluator (Print & Sign)	Date	Candidate	Date
_____	_____	_____	_____
Re-Test Evaluator	Date	Re-Test Candidate	Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-4 RESCUE OPERATIONS

Evaluation Sheet: 6-4.1C

6-4.1 EXTRICATE A VICTIM – MOTOR VEHICLE

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-4.1C NFPA 1001, 2008 Edition		TASK: Set up and Operate Hydraulic Rescue Shears/Cutters.			
PERFORMANCE OUTCOME: The candidate, wearing full protective clothing and eye protection, shall demonstrate the proper set-up and use of Hydraulic Rescue Shears/Cutters. An assistant may operate the hydraulic pump under the direction of the candidate.					
CONDITIONS: Given personal protective clothing (boots, pants, coat, hood, gloves, eye protection, and helmet), Hydraulic Rescue Shears/Cutters, hydraulic pump, and connectors, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Inspect all furnished hydraulic equipment for damage				
2.	Position hydraulic pump outside the work area within hose reach of the scene				
3.	Connect the shears/cutting tool to the pump with secure connections				
4.	Open the blade arms				
5.	Grasp the work to be cut, at the proper angle, well back into the blades				
6.	Safely operate the shears/cutting arms to cut the object				
7.	Open the blade arms fully and remove the shears/cutting arms from the work				
8.	Repeat steps 4-8, to make any additional cuts called for				
9.	Close the shear/cutter arms				
10.	Disconnect the rescue shears from the pump				
11.	Place the rescue shears and all components in the designated area in a ready state for reuse				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-4 RESCUE OPERATIONS

Evaluation Sheet: 6-4.1D

6-4.1 EXTRICATE A VICTIM – MOTOR VEHICLE

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-4.1D NFPA 1001, 2008 Edition		TASK: Set up and operate a Hydraulic Extension Ram.			
PERFORMANCE OUTCOME: The candidate, wearing full protective clothing and eye protection, shall demonstrate the proper set-up and use of Hydraulic Extension Ram. An assistant may operate the hydraulic pump under the direction of the candidate.					
CONDITIONS: Given personal protective clothing (boots, pants, coat, hood, gloves, eye protection, and helmet), a Hydraulic Extension Ram, hydraulic pump, and connectors, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Inspect all furnished hydraulic equipment for damage				
2.	Position hydraulic pump outside the work area within hose reach of the scene				
3.	Connect the hydraulic extension ram to the pump with secure connections				
4.	Place the ram between the objects to be spread				
5.	Extend the ram arms until the desired extension is made				
6.	Retract the arms				
7.	Disconnect the ram from the pump				
8.	Place the ram and all components in the designated area in a ready state for reuse				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____ Evaluator (Print & Sign)	_____ Date	_____ Candidate	_____ Date
_____ Re-Test Evaluator	_____ Date	_____ Re-Test Candidate	_____ Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-4 RESCUE OPERATIONS

Evaluation Sheet: 6-4.1E

6-4.1 EXTRICATE A VICTIM – MOTOR VEHICLE

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-4.1E NFPA 1001, 2008 Edition		TASK: Set up and operate a Pneumatic Chisel/Hammer.			
PERFORMANCE OUTCOME: The candidate, wearing full protective clothing and eye protection, shall demonstrate the proper use of a Pneumatic Chisel/Hammer. An assistant may run the pneumatic source under the direction of the candidate.					
CONDITIONS: Given personal protective clothing (boots, pants, coat, hood, gloves, eye protection, and helmet), and a Pneumatic Chisel/Hammer, pneumatic source, and all connectors, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Inspect the equipment for damage				
2.	Check the area for hazards or flammable vapors				
3.	Attach the appropriate cutting bit to the hammer				
4.	Connect the regulator, hose, and hammer so it is ready to operate				
5.	Power the device and adjust the pressure as necessary				
6.	Operate the hammer, maintain control, and cut the material as directed				
7.	Disassemble the equipment				
8.	Place the hammer and all components in the designated area in a ready state for reuse				
RETEST APPROVED BY: _____			RETEST EVALUATOR: _____		

Evaluator/Candidate Comments: _____

_____ Evaluator (Print & Sign)	_____ Date	_____ Candidate	_____ Date
_____ Re-Test Evaluator	_____ Date	_____ Re-Test Candidate	_____ Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-4 RESCUE OPERATIONS

Evaluation Sheet: 6-4.1F

6-4.1 EXTRICATE A VICTIM – MOTOR VEHICLE

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-4.1F NFPA 1001, 2008 Edition		TASK: Set up and operate a Hydraulic Jack and stabilize a vehicle with cribbing.			
PERFORMANCE OUTCOME: The candidate, wearing full protective clothing and eye protection, shall demonstrate the proper use of a Hydraulic Jack.					
CONDITIONS: Given personal protective clothing (boots, pants, coat, hood, gloves, eye protection, and helmet), a Hydraulic Jack, base plate material, wooden wedges, and assorted cribbing, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Inspect the equipment for damage				
2.	Assess for a solid, flat jacking surface				
3.	Place a board or plate where jack base will sit and shim level, if necessary				
4.	Position jack under solid area of the load, fully retracted				
5.	Close pressure release valve				
6.	Lift the vehicle				
7.	Stack cribbing in a box formation under the load during the lift				
8.	Place sufficient cribbing (possibly in multiple locations) to support the load				
9.	Retract the jack to allow load to rest on cribbing				
10.	Check the load for stabilization				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____ Evaluator (Print & Sign)	_____ Date	_____ Candidate	_____ Date
_____ Re-Test Evaluator	_____ Date	_____ Re-Test Candidate	_____ Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

**6-4 RESCUE OPERATIONS
6-4.2 ASSIST RESCUE OPERATIONS TEAMS**

Evaluation Sheet: 6-4.2

Candidate: _____ **Date:** _____
Birth Date _____
Mo Day Yr _____ **Last 4 digits of SS#:** _____

STANDARD: 6-4.2 NFPA 1001, 2008 Edition		TASK: Assist rescue teams during a specialized rescue.			
PERFORMANCE OUTCOME: While operating under the direction of a specialized rescue team, the candidate shall be able to assist by following procedures, quickly recognizing and retrieving rescue items, and completing assignments.					
CONDITIONS: Given a special rescue scenario, standard operating procedures, necessary rescue equipment, and assignment direction, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Identify and retrieve the tools and equipment commonly used to perform a special rescue				
2.	Establish public barriers so that bystanders are isolated from the rescue scene				
3.	Assist rescue teams by completing assigned tasks for one of the following scenarios (choose one):				
	a. Structural collapse				
	b. Trench collapse				
	c. Cave and/or tunnel emergencies				
	d. Water and/or ice emergencies				
	e. Elevator emergencies				
	f. Escalator emergencies				
	g. Energized electrical line emergencies				
	h. Industrial accidents				
RETEST APPROVED BY: _____			RETEST EVALUATOR: _____		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-5 PREVENTION, PREPAREDNESS, AND MAINTENANCE

Evaluation Sheet: 6-5.1

6-5.1 PERFORM A FIRE SAFETY SURVEY IN A PRIVATE DWELLING

Candidate: _____

Date: _____

Birth Date

Mo Day Yr _____

Last 4 digits of SS#: _____

STANDARD: 6-5.1 NFPA 1001, 2008 Edition		TASK: Perform a fire safety survey in a private dwelling.			
PERFORMANCE OUTCOME: Using local procedures and forms, the candidate will perform a fire safety survey in a local private dwelling.					
CONDITIONS: Using local procedures and form, the candidate will perform a fire safety survey in a local private dwelling.					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Proper introduction to homeowner				
2.	Check for common fire hazards (electrical, cooking, storage of flammables, etc.)				
3.	Check smoke detector (heat detector and co-detector, if present) and Exit Drill procedure				
4.	Check heating system(s) (including fireplace)				
5.	Check for structural hazards (chimney, disrepair, etc.)				
6.	Check for combustible waste removal (trash, sawdust, paper, etc.)				
7.	Properly fill out required forms of department				
8.	Findings match recommendations				
9.	Communicate findings to owner				
10.	Thank owner				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign)

Date

Candidate

Date

Re-Test Evaluator

Date

Re-Test Candidate

Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-5 PREVENTION, PREPAREDNESS, AND MAINTENANCE

Evaluation Sheet: 6-5.2

6-5.2 PRESENT FIRE SAFETY INFORMATION

Candidate: _____
Birth Date _____
Mo Day Yr _____

Date: _____
Last 4 digits of SS#: _____

STANDARD: 6-5.2 NFPA 1001, 2008 Edition		TASK: Present fire safety information to station visitors or small groups.			
PERFORMANCE OUTCOME: Using local procedures or lesson plans, the candidate shall present fire safety information to small groups or conduct a fire station tour.					
CONDITIONS: Using local procedures or lesson plans, the candidate will present a fire safety lesson or conduct a station tour.					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	a. Lesson title of subject taught; or				
	b. Station tour				
2.	Number of participants				
3.	Age group				
4.	Successfully teach lesson; OR				
5.	Successfully present a station tour				
6.	Fill out Public Fire Education Report Form correctly				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

_____ Evaluator (Print & Sign)	_____ Date	_____ Candidate	_____ Date
_____ Re-Test Evaluator	_____ Date	_____ Re-Test Candidate	_____ Date



FIREFIGHTER II

Instruction Sheet:

NFPA 1001, 6-5.2: Present a prepared program to an identified audience, given a lesson plan, time allotment, and instructional materials. Suggested topics: stop, drop, and roll; crawl low in smoke; escape planning; alerting others; calling the fire department; fire station tour; residential smoke detector placement and maintenance; or other fire prevention lesson.

DIRECTIONS: This objective requires the firefighter to teach a public fire education/prevention class. The intended audience is the general public. This lesson may be taught to a wide variety of audiences. A partial list of possible audiences are school children, adults, church groups, public service groups or other members of the general public, day care centers, nursing homes, and Sunday schools.

Lesson plans for this presentation can be found in the NFPA Learn Not To Burn Curriculum and the Kids Safe Fire Safety Program. Many individual fire department fire prevention programs also have lesson plans that can be used.

After teaching this lesson, complete the form. The form will document the necessary information for you to receive credit for the activity.

Public Fire Education Report Form

Presenter's Name _____

Fire Department _____

Type of Public Education (circle one) **Lesson** **Station Tour**

If Lesson, Title of Lesson _____

Number of participants _____

Age Group of Participants (circle one)

Preschool Grade School Middle/Jr.High High School Adult

Did you use an evaluation sheet. **Yes** **No**

Give your evaluation of the class. Include comments on how the participants responded to the class.

Candidate's Signature _____



FIREFIGHTER II

6-5 PREVENTION, PREPAREDNESS, AND MAINTENANCE

Evaluation Sheet: 6-5.3

6-5.3 PREPARE A PRE-INCIDENT SURVEY

Candidate: _____

Date: _____

Birth Date

Mo Day Yr

Last 4 digits of SS#: _____

STANDARD: 6-5.3 NFPA 1001, 2008 Edition		TASK: Prepare a pre-incident survey.			
PERFORMANCE OUTCOME: The candidate shall be able to prepare a pre-incident survey so that all required occupancy information is recorded, items of concern are noted, and accurate diagrams are prepared.					
CONDITIONS: Given a pre-incident survey form, necessary tools, and survey information, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Appropriately notify the building occupant and arrange to complete the field survey				
2.	Identify the components of fire suppression and detection systems to include in the survey				
3.	Sketch the site, buildings, and applicable special features				
4.	Detect applicable hazards to include in the pre-incident drawings				
5.	Detect applicable special considerations to include in the pre-incident diagrams				
6.	Complete all related departmental forms and final diagrams				
7.	Route, file, and/or forward report in accordance with local agency criteria				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign)

Date

Candidate

Date

Re-Test Evaluator

Date

Re-Test Candidate

Date



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

6-5 PREVENTION, PREPAREDNESS, AND MAINTENANCE

Evaluation Sheet: 6-5.4

6-5.4 MAINTAIN POWER PLANTS, TOOLS, AND LIGHTING EQUIPMENT

Candidate: _____

Date: _____

Birth Date

Mo Day Yr _____

Last 4 digits of SS#: _____

STANDARD: 6-5.4 NFPA 1001, 2008 Edition		TASK: Maintain power plants, power tools, and lighting equipment.			
PERFORMANCE OUTCOME: The candidate shall be able to maintain power plants, power tools, and lighting equipment so that equipment is clean and maintained according to manufacturer's and departmental guidelines, completed maintenance is recorded, and equipment is placed in a ready state or reported otherwise.					
CONDITIONS: Given the appropriate tools and manufacturer's instructions, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Inspect power plants, power tools, and lighting equipment to ensure they are in a ready state				
2.	Start and properly operate power plants, power tools, and lighting equipment				
3.	Select the correct tools used for maintaining power plants, power tools, and lighting equipment				
4.	Follow the guidelines for maintaining power plants, power tools, and lighting equipment				
5.	Complete all applicable recording and reporting procedures, according to local agency criteria				
6.	Report out-of-service equipment according to local agency criteria				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**



**FIRE PROTECTION BUREAU
STANDARDS AND ACCREDITATION
PO Box 42600
Olympia WA 98504-2600
(360) 596-3931 FAX: (360) 596-3936**



FIREFIGHTER II

**6-5 PREVENTION, PREPAREDNESS, AND MAINTENANCE
6-5.5 PERFORM AN ANNUAL SERVICE TEST ON FIRE HOSE**

Evaluation Sheet: 6-5.5

Candidate: _____ **Date:** _____
Birth Date _____
Mo Day Yr _____ **Last 4 digits of SS#:** _____

STANDARD: 6-5.5 NFPA 1001, 2008 Edition		TASK: Perform an annual service test on fire hose.			
PERFORMANCE OUTCOME: The candidate shall be able to, according to standard procedures, perform an annual service test of fire hose so that the condition is evaluated, damaged hose is removed from service, and the results are recorded.					
CONDITIONS: Given a pump, a marking device, pressure gauges, a timer, recordkeeping materials, and related equipment, the candidate shall demonstrate the ability to:					
No.	TASK STEPS	FIRST TEST		RETEST	
		Pass	Fail	Pass	Fail
1.	Mark hose directly behind coupling, inspect gasket condition, and visually inspect hose for damage				
2.	Assemble hoselines to a maximum length of 300 feet and connect to a discharge port with a restricted flow				
3.	Charge lines, bleed air from all lines, check for leaks, and tighten couplings as needed				
4.	Operate hose-testing equipment so that all hose lines are pressurized to 250 psi and maintain for 5 minutes				
5.	Decrease pressure, bleed lines, and inspect each hose for any slipped couplings				
6.	Complete all applicable recording and reporting procedures, according to local agency criteria				
7.	Report any out-of-service hose, according to local agency criteria				
RETEST APPROVED BY:			RETEST EVALUATOR:		

Evaluator/Candidate Comments: _____

Evaluator (Print & Sign) **Date** **Candidate** **Date**

Re-Test Evaluator **Date** **Re-Test Candidate** **Date**