

**Washington State Patrol Releases - December Death Investigation**  
**Evergreen State College Student Died of Carbon Monoxide Poisoning 12/11/23**  
**Timeline of Events:**

- December 4, 2023
  - A new tankless water heater is installed in the unit by an outside vendor
- December 11, 2023 (MORNING)
  - 5:41 A.M.
  - 5:58 A.M.
  - 5:59 A.M.
  - 6:17 A.M.
  - 6:18 A.M.
  - 6:20 A.M. (estimated)
  - 6:30 A.M.
  - 7:15 A.M.
  - 8:07 A.M.
  - 8:47 A.M.
  - 8:49 A.M.
  - 8:59 A.M.
  - 9:30 A.M.
  - 9:47 A.M.
  - 10:10 A.M.
  - 10:11 A.M.
  - 10:00-11:00 A.M. (estimated)
- CO alarms begin to sound
- Resident calls TESC Dispatch
- Dispatch calls Residential Maintenance (RM) (Gets voice mail)
- Resident calls TESC Dispatch again
- Dispatch calls RM again (RM leaves for MOD# 305)
- RM arrives at #305 (Residents are outside) (RM hears alarm and call supervisor) (RM attempt to clean/clear CO devices)
- RM Checks fire panel/confirms CO alarms (Calls supervisor again) (Residents go back inside)
- Supervisor arrives (Opens windows and doors) (Attempts to clean CO devices) (Calls for additional assistance)
- Alarm Panel is silenced (Resident sends text to friend saying alarms are finally silent)
- Alarms begin sounding again
- TESC calls security system supplier (Supplier recommends cleaning devices) (Advises putting in a work order)
- Alarm Panel silenced/several resets done
- TESC removes CO devices from Bedrooms A,B,C,D and F (Device left in Room E)
- TESC calls supplier/work order created)
- CO Alarm sounds in Room E
- Alarm Panel silenced
- Windows and doors closed (Residents informed security system supplier would be coming out later to troubleshoot)

## **Timeline of Events (Cont.)**

- December 11, 2023 (EVENING)
  - 6:16 P.M.
  - 7:00 P.M. (estimated)
  - 7:29 P.M.
  - 7:30 – 8:00 P.M.
  - 8:04 P.M.
  - 8:10 P.M.
  - 8:10 P.M.
  - 8:12 P.M.
  - 8:20 P.M.
- Security system supplier arrives at TESC  
(Begins troubleshooting)
- CO devices reinstalled/reset in #305
- CO Alarm sounds
- Communications between TESC Dispatch  
and RM re: continued alarms
- RM advised Dispatch they are checking  
#305 for possible CO leak
- RM advises Dispatch they see 2 people  
in distress  
(They open windows for ventilation)
- Dispatch notifies TESC officer
- TESC officer arrives and starts first aid  
(2 students found in Bedroom B)  
(1 student found in Bedroom F)
- Fire Department arrives